## MICROBIOLOGY REPORT



# LMS TECHNOLOGIES, INC.

6423 Cecilia Circle Bloomington, MN 55439 USA

Date: August 17, 2020 Test Requested by: Genesis

Test Type: Viral Single-Pass Efficiency Contact: Dan Briggs

#### Scope

1 device and 2 Pre-filters submitted by Genesis Air for single-pass efficiency testing with MS-2 bacteriophage (ATCC 15597-B1) as the challenge organism.


#### Method

The single-pass efficiency tests were conducted in a horizontal ASHRAE 52.2 stainless-steel test duct with a cross-sectional dimension of 24"x24". The tests were performed under positive pressure with a blower pushing air through the filter and removal device. The test system airflow for all 24"x24"x2" and 4" filters Were 1180, 1496 and 1968 corresponding to test air velocity of 295, 374 and 492 fpm.

Organism were grown on appropriate media, harvested, and resuspended in saline to  $5x10^6$  pfu/ml. Suspensions of the organisms were then aerosolized into the test duct using a nebulizer situated 8-feet upstream of the test filter. While the challenge aerosol was injected into the test duct, both upstream and downstream air samples were taken using SKC Bio-Stage cascade impactors for 5-minutes at calibrated sampling rates of 28 liters/min. This was repeated few times to collect statistically valid number of organisms. Also, SKC impinger were utilized to collect samples when high concentrations of challenge organisms were used for testing.

Tel: 952-918-9060

Fax: 952-918-9061



Particle size distribution of challenge virus



Prefilter



Filter with UV lights

### Data:

Device +	Upstream cfus	Downstream cfus	Efficiency
MPA8-24244	43200	302	99.3%
MPA9-24244	43200	362	99.2%

Test data for 1180 cfm (295 fpm)

Device +	Upstream cfus	Downstream cfus	Efficiency
MPA8-24244	34800	125	99.6%
MPA9-24244	34800	206	99.4%

Test data for 1496 cfm (374 fpm)

	Upstream	Downstream	
Device +	cfus	cfus	Efficiency
MPA8-24244	27000	70	99.7%
MPA9-24244	27000	121	99.6%

Test data for 1968 cfm (492 fpm)